



FRONT VIEW
SIDE VIEW
TYPE III-CF SERVICE EQUIPMENT ENCLOSURE (TYPICAL)
DETAIL A



BASE FOR TYPE III-C SERVICE EQUIPMENT ENCLOSURE
DETAIL B



120/240 V SERVICE WIRING DIAGRAM (TYPICAL)
DETAIL C

TYPE III-C SERVICE EQUIPMENT ENCLOSURE LEGEND (120/240 V)

ITEM	COMPONENT	NAMEPLATE DESCRIPTION	ITEM	COMPONENT	NAMEPLATE DESCRIPTION
(1)	NEUTRAL LUG		(14)	30 A, 240 V, 2P, CB	SIGN ILLUMINATION
(2)	LANDING LUG		(15)	100 A, 240 V, 2P, CB	MAIN BREAKER
(3)	TEST BYPASS FACILITY		(16)	30 A, 240 V, 2P, CB	LIGHTING
(4)	METER SOCKET AND SUPPORT		(17)	50 A, 120 V, 1P, CB	SIGNALS
(5)	TERMINAL BLOCKS		(18)	30 A, 120 V, 1P, CB	RAMP METERING
(6)	NEUTRAL BUS		(19)	20 A, 120 V, 1P, CB	IRRIGATION
(7)	GROUND BUS		(20)	15 A, 120 V, 1P, CB	LIGHTING CONTROL
(8)	GROUNDING ELECTRODE		(21)	15 A, 1P, TEST SWITCH	IISNS TEST SWITCH
(9)	30 A, 2P, NO CONTACTOR	SIGN ILLUMINATION	(22)	15 A, 1P, TEST SWITCH	LIGHTING TEST SWITCH
(10)	PHOTOELECTRIC UNIT (NOTE 4)	PEU	(23)	60 A, 2P, NO CONTACTOR	LIGHTING
(11)	15 A, 1P, TEST SWITCH	SIGN ILLUMINATION TEST SWITCH	(24)	15 A, 120 V, 1P, CB	IISNS
(12)	15 A, 120 V, 1P, CB	SIGN ILLUMINATION CONTROL	(25)	30 A, 2P, NO CONTACTOR	IISNS
(13)	15 A, 120 V, 1P, CB	FLASHING BEACON	(26)	20 A, 120 V, 1P, CB	TELEPHONE DEMARCATION CABINET
			(27)	15 A, 120 V, 1P, CB	IISNS CONTROL

- NOTES:**
- Unless otherwise indicated on the plans, service equipment items shall be provided for each service equipment enclosure as shown.
 - Connect to remote test switch mounted on lighting standards, sign post or structure when required.
 - Items (1) and (6) shall be isolated from the service equipment enclosure.
 - Type I photoelectric control shall be used unless otherwise indicated on the plans.
 - Item (12), (20) and (27) shall be ganged operated CB.

STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION
ELECTRICAL SYSTEMS
(SERVICE EQUIPMENT ENCLOSURE AND
TYPICAL WIRING DIAGRAM,
TYPE III-C SERIES)

NO SCALE

RSP ES-2F DATED JULY 21, 2017 SUPERSEDES STANDARD PLAN ES-2F
DATED OCTOBER 30, 2015 - PAGE 426 OF THE STANDARD PLANS BOOK DATED 2015.
REVISED STANDARD PLAN RSP ES-2F

DIST#	COUNTY	ROUTE	POST MILES TOTAL PROJECT	SHEET NO.	TOTAL SHEETS
-------	--------	-------	--------------------------	-----------	--------------

REGISTERED ELECTRICAL ENGINEER
H. R. F.
Hamid Zolfaghari
No. E15636
PLANS APPROVAL DATE
July 21, 2017
TO ACCOMPANY PLANS DATED _____

PROFESSIONAL ENGINEER
Hamid Zolfaghari
No. E15636
Exp. 12-31-17
ELECTRICAL
STATE OF CALIFORNIA

THE STATE OF CALIFORNIA OR ITS OFFICERS OR AGENTS SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF SCANNED COPIES OF THIS PLAN SHEET.

2015 REVISED STANDARD PLAN RSP ES-2F