






LEGEND:


-  10" x 6" x 1'-0" FILLER BLOCK ALIGNED AGAINST HEADER.
-  10" x 6" STRETCHERS
- LC1 = LOADING CASE I
- LC2 = LOADING CASE II
- y = 4 AND 6 FOR BATTERED FOR TYPES A, B, AND C

MAXIMUM WALL HEIGHTS						
BATTER	TYPE A		TYPE B		TYPE C	
	LC1	LC2	LC1	LC2	LC1	LC2
VERTICAL	24'-0"	11'-0"	27'-0"	20'-0"	31'-0"	27'-0"
1:6	31'-0"	13'-0"	36'-0"	23'-0"	36'-0"	33'-0"
1:4	33'-0"	15'-0"	36'-0"	25'-0"	36'-0"	36'-0"


Dist#	COUNTY	ROUTE	POST MILES TOTAL PROJECT	SHEET No.	TOTAL SHEETS
 REGISTERED CIVIL ENGINEER					
May 31, 2018 PLANS APPROVAL DATE					
THE STATE OF CALIFORNIA OR ITS OFFICERS OR AGENTS SHALL NOT BE RESPONSIBLE FOR THE ACCURACY, OR COMPLETENESS, OR SCANNED COPIES OF THIS PLAN SHEET.					
					



TYPE A



TYPE B



TYPE C

STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION
**REINFORCED CONCRETE CRIB WALL
TYPES A, B AND C**

NO SCALE

C7A