

DIGEST OF REVISIONS

2015 STANDARD PLANS ERRATUM NO. 2

April 15, 2016

GENERAL

For the 2015 edition Standards, Revised Standard Plans are new or revised standard plans.

The listed Revised Standard Plans (RSPs) supersede the comparable standard plans in the 2015 edition Standard Plans book or supplement the 2015 edition Standard Plans book.

PLAN SPECIFIC

PLAN NO.	CHANGES
RSP H8	<ul style="list-style-type: none"> In the "Irrigation Conduit - Under Sidewalks, Driveways, and Paths" detail - changed title and call out to "PVC Pipe Conduit Sleeve."
RSP ES-1C	<ul style="list-style-type: none"> Changed terminology from equipment identification number to equipment identification character.
RSP ES-3B	<ul style="list-style-type: none"> Removed Notes 1, 4, and 5 and moved to the specifications.
RSP ES-3C	<ul style="list-style-type: none"> Removed Note 1 and moved to the specifications. Added 2" dimension from finished grade to top of concrete pad.
RSP ES-3D	<ul style="list-style-type: none"> Revised foundation information in the notes.
RSP ES-3E	<ul style="list-style-type: none"> In Detail B, added 2" dimension from finished grade to top of concrete pad and 6" dimension from finished grade to top of foundation.
RSP ES-3F	<ul style="list-style-type: none"> In Detail D, added 1'-8" dimension from finished grade to top of foundation.
RSP ES-3I	<ul style="list-style-type: none"> Changed the title of the sheet to "Electrical Systems (Electronics Assembly Connection Diagram, with Bypass Control Line).
RSP ES-3J	<ul style="list-style-type: none"> Changed the title of the sheet to "Electrical Systems (Electronics Assembly Connection Diagram, with Bypass Control Line).
RSP ES-3K	<ul style="list-style-type: none"> Changed the title of the sheet to "Electrical Systems (Electronics Assembly Connection Diagram, without Bypass Control Line).
RSP ES-3L	<ul style="list-style-type: none"> Changed the title of the sheet to "Electrical Systems (Electronics Assembly Connection Diagram, without Bypass Control Line).
RSP ES-5A	<ul style="list-style-type: none"> Removed dimensions in the saw cut details.
RSP ES-5B	<ul style="list-style-type: none"> Revised Note 3 to "Use Type D loops for limit line detection and bicycle lanes."
RSP ES-7J	<ul style="list-style-type: none"> Removed "Advance" from flashing beacon terminology. Revised Detail A and Detail D by removing photoelectric control unit and adapter, sign lighting fixture and Type 1 conduit.
RSP ES-7K	<ul style="list-style-type: none"> Revised Note 3 to "Vertical clearance shall be 17'-0" minimum between roadway and bottom of signal panel." and revised details, accordingly. Removed Notes 4 and 5 and moved to the specifications. Revised Elevation A by removing photoelectric control unit and adapter.
RSP ES-7L	<ul style="list-style-type: none"> Removed Details D, E, and F.
RSP ES-8A	<ul style="list-style-type: none"> Removed Note 1 and moved to specifications. On Cover Top View, revised cover marking area and changed tier rating to load rating.
RSP ES-8B	<ul style="list-style-type: none"> Removed Note 3 and moved to specifications. On Top View, added cover marking area and added load rating.
RSP ES-9C	<ul style="list-style-type: none"> Revised various detail titles to match format changed on sheet ES-1C.
RSP ES-9D	<ul style="list-style-type: none"> In Detail A, removed call out "For railing on retaining wall, extend box through entire curb and provide bottom drain and crushed rock sump as shown on Standard Plans ES-8A and ES-8B."

DIGEST OF REVISIONS
2015 STANDARD PLANS ERRATUM NO. 2

RSP ES-9E	<ul style="list-style-type: none">• In Detail P, replaced asterisk symbol (*) with diameter symbol (Ø) and added "suspension conduit" to clarify the 3/4" C min length.
RSP ES-13A	<ul style="list-style-type: none">• Added and revised splice insulation details.• Changed sheet title to "Electrical Systems (Splice Insulation Methods Details).
RSP ES-13B	<ul style="list-style-type: none">• Revised HPS lamp ballast and low pressure sodium ballast information in the table.
RSP ES-14B	<ul style="list-style-type: none">• Revised Detail B.
ES-15B (canceled)	<ul style="list-style-type: none">• Canceled this standard plan.